

Petreski, Sonya

From: James Lindley <James.Lindley@aemo.com.au>
Sent: Thursday, 26 March 2020 6:10 PM
To: Chan, David
Cc: Gannon, Rob; Babak Badrzadeh
Subject: RE: West Murray Zone solar farm voltage control issues [SEC=OFFICIAL:Sensitive] [ACCC-ACCCANDAER.FID1813251]
Attachments: ESIG-High Share of IBGTF.pptx

Hello David,

Attached is an updated presentation developed by Babak Badrzadeh, originally presented at ESIG Fall Workshop in October 2019. It addresses both aspects of "understand the underlying phenomena of the issues, and what is being done to correct this issue".

Kind regards,

James

From: James Lindley
Sent: Thursday, 19 March 2020 22:20
To: Chan, David <david.chan@aer.gov.au>
Cc: Gannon, Rob <Rob.Gannon@aer.gov.au>; Babak Badrzadeh <Babak.Badrzadeh@aemo.com.au>
Subject: RE: West Murray Zone solar farm voltage control issues [SEC=OFFICIAL:Sensitive] [ACCC-ACCCANDAER.FID1813251]

Hello David,

Thanks for the conversation today, and I can confirm that we will pull the requested information together for you. Hopefully we can get this done in the next few days (we are a bit under the pump at the moment) – if it will take longer we will let you know.

Kind regards

James

From: Chan, David <david.chan@aer.gov.au>
Sent: Thursday, 19 March 2020 15:44
To: James Lindley <James.Lindley@aemo.com.au>
Cc: Gannon, Rob <Rob.Gannon@aer.gov.au>
Subject: West Murray Zone solar farm voltage control issues [SEC=OFFICIAL:Sensitive] [ACCC-ACCCANDAER.FID1813251]

OFFICIAL:Sensitive

James

I would appreciate if you can provide us an update on the main causes of the voltage fluctuation problems.

Released under FOI

This information will help us in:

- 
- To inform the AER Board on this matter.

Regards

David Chan

Director

Compliance & Enforcement Branch

Australian Energy Regulator

Casselden Place

Level 17, 2 Lonsdale St

Melbourne VIC 3000

T: 03 9290 1446

E: david.chan@aer.gov.au

IMPORTANT: This email from the Australian Energy Regulator (AER), and any attachments to it, may contain information that is confidential and may also be the subject of legal, professional or other privilege. If you are not the intended recipient, you must not review, copy, disseminate, disclose to others or take action in reliance on, any material contained within this email. If you have received this email in error, please let the AER know by reply email to the sender informing them of the mistake and delete all copies from your computer system. For the purposes of the Spam Act 2003, this email is authorised by the AER www.aer.gov.au

This email, including all attachments, is confidential and for the sole use of the intended recipient(s). If you are not the intended recipient, you are prohibited from disclosing, copying, distributing, or in any other way using it. If you have received this email in error, please notify me by return email, or contact the AEMO Information and Support Hub on 1300 236 600, and then delete this email from your system.

Released under FOI



Practical example of assessing
and mitigating issues associated
with operation of inverter-based
generation in Australian National
Electricity Market

Babak Badrzadeh
Australian Energy Market Operator

Released under FOI

Problem statement


Released under FOI



Inverter-based generator connection sparsity

- Far from capable synchronous generators
- Close to other inverter-based generation

Lack of system strength is one of the key challenges




The need to design generating plant capable of operating in such networks

Released under FOI



Sustained post-disturbance sub-synchronous oscillations



- Oscillations unacceptable due to:
 - Breach of system security and flicker requirements
 - Impact on load/connected equipment


Released under FOI

Appropriate simulation tools

Released under FOI

EMT vs RMS models

- AEMO has developed full-scale EMT models of all five South Eastern regions that it operates to assess:
 - High penetration of inverter-based generators
 - Lack of system strength
- EMT models were not available at the time of assessing respective connection applications



RMS models are not suitable for assessing sub- or super-synchronous oscillations

Released under FOI

Withstand capability of
inverter-based generators
to lack of system strength

Released under FOI

Basic definition of short circuit ratio

- Inverter-based generators are designed to withstand down to a certain level of system strength.
 - This is often characterised by short circuit ratio (and its variations), sometimes combined by X/R ratio.
 - This withstand capability depends on the response of inverter control system
- Definition of short circuit ratio

$$SCR_{POI} = \frac{\text{fault MVA}_{POI}}{P_{RAT}}$$



$$SCR_{POI} = \frac{\text{fault MVA}_{POI}}{S_{RAT}}$$


Released under FOI

Example of sustained post-
disturbance oscillations


Released under FOI

All solar inverters and SVCs are in service

Asynchronous Voltage



Asynchronous Active Power




unacceptable post-fault oscillations


Released under FOI

All solar inverters are in service with all SVCs out of service

Asynchronous Voltage



Asynchronous Active Power




oscillations are further exacerbated


Released under FOI

35% of inverters are in service

Asynchronous Voltage



Asynchronous Active Power




practically no voltage oscillations


Released under FOI

All inverters are in service but dispatched at 35% of nominal power

Asynchronous Voltage



Asynchronous Active Power




Unacceptable post-fault oscillations


Released under FOI

35% of solar inverters are in service with a prior network line outage

Asynchronous Voltage



Asynchronous Active Power




Time (s) larger oscillations due to prior outage Time (s)


Released under FOI

10% of solar inverters are in service with a prior transmission line outage

Asynchronous Voltage



Asynchronous Active Power



further reduction in number of inverters

Released under FOI

Mitigation measures

Temporary constraints

- A reduced number of inverters limits the oscillations within acceptable levels (currently applied)

Inverter control system/parameter changes

- Retuning the control parameters or refining the control strategy of the impacted inverters limits the oscillations within acceptable levels or removes the oscillations altogether (being finalised)

Installation of nearby synchronous machines

- Installation of nearby synchronous machines increases the system strength available to the inverters in a remote and sparse part of the network (installation of network synchronous condensers following system strength shortfall declaration)

Released under FOI

