
From: STEPHEN BREHENY
Sent: Tuesday, 14 May 2019 8:18 AM
To: Adjudication
Subject: Industry-wide Code

Categories: Submission

Dear Sir/Madam,

After having a meeting with the local Fire Brigade, we discussed the possibility of having the Circuit Breakers controlling the Solar Supply Main Switch and Battery Supply Main Switch be a distinctive colour for example an ALL-RED CIRCUIT BREAKER or other appropriate colour.

With the profuse signage in the switchboards now The CFA members all agreed that the isolation switches are very confusing. They said it is nearly impossible to determine which switch is to be isolated when under pressure (during a fire). Especially now that the main switch may not necessarily turn off the power due to a battery back-up.

Kind regards
Stephen Breheny



SB Solar Battery Pty. Ltd

Electrical Contractor &
Grid Connect & Stand Alone Solar
Designer & Installer
ABN 69 353 817 347
Solar Lic. A7299940
Electrical Contractor Lic. 9415
www.stephenbreheny.com.au

PH. 1300 103 889