

**Pfitzner, Laura**

---

**From:** Jeffery Bye <jeffbye@demandmanager.com.au>  
**Sent:** Thursday, 7 May 2015 1:47 PM  
**To:** Adjudication  
**Subject:** A91495 & A91496 – CEC – submission

Thank you for your invitation to submit comments on the Clean Energy Council's proposed amendments to the Voluntary Code of Conduct.

Demand Manager is an active participant in the solar market through STC aggregation services and a newly created solar PPA product, hence we see value in the proposed amendments and support them.

We would, however, like to see the Code of Conduct strengthened with regards to the metering solutions proposed for PPA products. Demand Manager is concerned that sub-standard metering solutions may result that do not comply with the standards expressed in the National Metering Institute NMI M 6-1 requirements. In particular, we would suggest that metering a PPA product from an inverter display is not accepted as accurate enough for billing purposes and that the metering solution must involve the installation of a pattern approved meter.

Thanks again for the opportunity.

Regards  
Jeff

Sent from Windows Mail